

November 4, 2009

INVITATION TO TENDER "ITT" NO. PS09181
SUPPLY AND INSTALLATION OF CAR PARK AND PATHWAY ELECTRICAL AT OLYMPIC
VILLAGE STATION LANDSCAPING

AMENDMENT NO. 2

RE: AMENDMENT NO. 1, APPENDIX 3 - DETAILED DRAWINGS: Attachment C - Specifications and Drawing Details (Drawing No. E2)

CURRENTLY READS:

Type	Description	Catalogue No.	Volt/ Ballast	Lamps No.	Lamps Type (Each)	Mounting	Remarks
'A'	POST LUMINAIRES, TYPE III, SINGLE HEAD ON 25' HIGH 125mm (5") SQUARE POLE. RAL9005 (BLACK FINISH)	EMCO AVALUME TYPE 3 - 100W MH	120V	1	1000W MH	SINGLE HEAD	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER
'B'	POST LUMINAIRES, TYPE III, DOUBLE HEAD ON 25' HIGH 125mm (5") SQUARE POLE. RAL9005 (BLACK FINISH)	EMCO AVALUME TYPE 3 - 100W MH	120V	2	1000W MH	DOUBLE HEAD	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER
'C'	POST TOP PEDESTRIAN PATHWAY LUMINAIRE, SINGLE HEAD ON 12' HIGH POLE. RAL9005 (BLACK) FINISH	<u>RUUD LIGHTING (The Edge) X-AR POST TOP, 2 BARS, TYPE II</u>	120V	1	<u>55W LED</u>	SINGLE HEAD <u>POST TOP</u>	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER, <u>INSTALLATION MOUNTING DIRECTION MARKED ON TOP OF LUMINAIRE. LUMINAIRES TO BE ALIGNED TO PATHWAY.</u>

**INVITATION TO TENDER "ITT" NO. PS09181
SUPPLY AND INSTALLATION OF CAR PARK AND PATHWAY ELECTRICAL AT OLYMPIC
VILLAGE STATION LANDSCAPING**

AMENDMENT NO. 2

'D'	POST TOP PEDESTRIAN PATHWAY LUMINAIRE, SINGLE HEAD ON 14' HIGH POLE. RAL9005 (BLACK) FINISH	EMCO AVALUME TYPE 3 - 100W MH	120V	1	1000W MH	SINGLE HEAD	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER
'F'	POST TOP STATION PLATFORM LUMINAIRE, <u>SINGLE HEAD ON 18' HIGH POLE. RAL9005 (BLACK) FINISH</u>	<u>RUUD LIGHTING (The Edge) X-AR POST TOP, 3 BARS, TYPE 60 DEGREE</u>	120V	1	<u>79W LED</u>	SINGLE HEAD <u>POST TOP</u>	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER

REPLACE WITH:

Type	Description	Catalogue No.	Volt/ Ballast	Lamps No.	Lamps Type (Each)	Mounting	Remarks
'A'	POST LUMINAIRES, TYPE III, SINGLE HEAD ON 25' HIGH 125mm (5") SQUARE POLE. RAL9005 (BLACK FINISH)	EMCO AVALUME TYPE 3 - 100W MH	120V	1	<u>100W MH</u>	SINGLE HEAD	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER
'B'	POST LUMINAIRES, TYPE III, DOUBLE HEAD ON 25' HIGH 125mm (5") SQUARE POLE. RAL9005 (BLACK FINISH)	EMCO AVALUME TYPE 3 - 100W MH	120V	2	<u>100W MH</u>	DOUBLE HEAD	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER
'C'	POST TOP PEDESTRIAN PATHWAY LUMINAIRE, SINGLE HEAD ON <u>12'</u> HIGH POLE. RAL9005 (BLACK) FINISH	<u>RUUD LIGHTING (The Edge) X-AR POST TOP, 2 BARS, TYPE II</u>	120V	1	<u>55W LED</u>	SINGLE HEAD <u>POST TOP</u>	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER, <u>INSTALLATION MOUNTING DIRECTION MARKED ON TOP OF LUMINAIRE. LUMINAIRES TO BE ALIGNED TO PATHWAY.</u>

**INVITATION TO TENDER "ITT" NO. PS09181
SUPPLY AND INSTALLATION OF CAR PARK AND PATHWAY ELECTRICAL AT OLYMPIC
VILLAGE STATION LANDSCAPING**

AMENDMENT NO. 2

'D'	POST TOP PEDESTRIAN PATHWAY LUMINAIRE, SINGLE HEAD ON 14' HIGH POLE. RAL9005 (BLACK) FINISH	EMCO AVALUME TYPE 3 - 100W MH	120V	1	<u>100W MH</u>	SINGLE HEAD	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER
'F'	POST TOP STATION PLATFORM LUMINAIRE, <u>SINGLE HEAD ON 18' HIGH POLE. RAL9005 (BLACK) FINISH</u>	<u>RUUD LIGHTING (The Edge) X-AR POST TOP, 3 BARS, TYPE 60 DEGREE</u>	120V	1	<u>79W LED</u>	SINGLE HEAD <u>POST TOP</u>	POLE AND LUMINAIRE SUPPLIED BY CITY OF VANCOUVER

All other conditions and specifications remain unchanged.

This amendment must be completed, and attached to your Tender form.

If you have already submitted your Tender, this amendment shall be submitted to Purchasing Services Office, 3rd Floor, Suite #320, East Tower, 555 West 12th Avenue, Vancouver, British Columbia, Canada, V5Z 3X7 in an envelope clearly marked "AMENDMENT NO. 2 TO ITT NO. PS09181: SUPPLY AND INSTALLATION OF CAR PARK AND PATHWAY ELECTRICAL AT OLYMPIC VILLAGE STATION LANDSCAPING" before the closing time of 3:00:00 P.M. Vancouver Time on Tuesday, November 10th, 2009

NAME OF VENDOR

SIGNATURE OF AUTHORIZED SIGNATORY

DATE

Julia Johnston
Buyer