

---

INVITATION TO TENDER "ITT" NO. PS10038  
NEW SIDEWALKS FOR PEDESTRIAN COLLECTOR ROUTES

QUESTIONS AND ANSWERS NO.2

ISSUED ON APRIL 6, 2010

Q1	Can you please clarify what the intended use of item 116 & 116B (Supply place & compact 19mm Granular Base) is for, as all the Concrete Items (Curb & Sidewalk) are to have granular base included in their unit bid price?
A1	<b>Items 116 &amp; 116B are intended for use as additional fill in areas of uneven ground that cannot be leveled or brought to the required sub-grade elevations through site grading. These pay items would be for material in addition to the required granular base included in other pay items.</b>