



- NOTES**
- DISCHARGE PIPING ON PUMPS #1 & 2 TO HAVE 50# M.A.S. G2 SS BALL VALVE C/W 50# CAP
 - ALL PIPING FOR GAUGES & PRESSURE TRANSMITTERS TO BE SCHED. 40 316 S.S.
 - SEE DRAWING 1972-410 FOR APPROXIMATE MOUNTING LOCATIONS. CONFIRM ALL MOUNTING LOCATIONS AND HEIGHTS WITH ENGINEER PRIOR TO INSTALLATION.
 - MOUNT UNISTRUT TO WALLS USING 6mm HILTI KWIK-BOLTS.

NO.	DATE	REVISION	DWG	DESIGN	NO.	DATE	REVISION	DWG	DESIGN
2	6/AUG/10	PRESS. TRANS. ASS'Y & HI LVL FLOAT DETAIL UPDATED	DL	DL					
1	3/AUG/10	ISSUED FOR TENDER	DL	DL					
P3	21/JUL/10	ISSUED FOR TENDER	DL	DL					
P2	11-06-10	ISSUED FOR REFERENCE MCC TENDER	DL	PD					

101 - 1861 Welch St.
North Vancouver B.C.
V7P 1B7 604-985-0508

ENGINEERING SERVICES - CITY OF VANCOUVER

KITSILANO PUMP STATION - MCC

PUMP STATION UPGRADES

MISCELLANEOUS DETAILS

SCALE: AS SHOWN

DATE: 07-MAY-2008

DRAWING NUMBER: 1972-300

SHEET...7...OF...21. REVISION:....2....

BRANCH	INITIALS	DATE
CHECKED		
CHECKED		

COVBRANCH	
DRAWN BY: DL	DESIGN BY: DL
CHECKED: PM	DESIGN CHECKED: PM
REFERENCES:	REFS:

