
BULLETIN 2000-025-EL

Revised September 4, 2015

RESIDENTIAL SUMP PUMPS

<p>The intent of this bulletin is to establish a uniform and consistent enforcement approach to the installation of residential sump pumps.</p>

Where a sump pump is installed to control water from a drainage system in residential occupancies, the following requirements must be met:

1. A receptacle shall be installed for the connection of the sump pump;
2. The receptacle for the sump pump shall be supplied by a branch circuit that supplies no other outlets or equipment;
3. The foregoing receptacle and branch circuit must be installed in conformance with the applicable requirements of the CE Code, Part 1; and
4. Only an approved double insulated sump pump assembly provided with a flexible cord and an attachment plug shall be installed.

(Original signed by)

W. White
MANAGER, TRADES INSPECTION
DEPUTY CITY ELECTRICIAN

(Original signed by)

P. Ryan, M.Sc., P.Eng.
CHIEF BUILDING OFFICIAL
DIRECTOR, BUILDING CODE & POLICY