

From: [Freedom of Information Office](#)
To: **s.22(1)**
Subject: FOI Request: Our File No. 2015-007 - res
Date: Friday, January 16, 2015 4:48:00 PM
Attachments: [document.pdf](#)

Dear **s.22(1)**,

Attached please find the Fire Permit you requested today for the underground storage tank removal at 4629 West 11th Avenue.

Regards,

Annie Goodwyne
FOI Clerk/Research Assistant
City Clerk's Office, City of Vancouver
(604) 873-7272
annie.goodwyne@vancouver.ca



CITY OF VANCOUVER



DATE ISSUED JULY 18, 2006		PERMIT TYPE FIRE PREVENTION DIVISION PERMIT				PERMIT NUMBER P FI 404834	
LEGAL DESCRIPTION LOT 17 OF 2 BLK 152 PL 3431 PLAN 3431 (cont'd)					ADDRESS 4629 W 11TH AV		
ADDITIONAL ADDRESS INFORMATION					SPECIFICS		
APPLICATION DATE JUL 18, 2006	PURPOSE REMOVAL	PROJECT VALUE	ASSESSED VALUE	PLANS	METRIC NO	PLACE NAME	
TEMPORARY PERMIT DATES		TEMPORARY USE DATES		SUBTYPE			
APPLICANT CONTRACTOR SNR SALVAGE AND RECOVERY 6179 DAWSON ST BURNABY BC V58 2W5					CONTACT 2 PROPERTY OWNER DEMPSTER VANCOUVER BC		
TEL 604-435-1722		BUS.LICENSE 295066		TEL 604-313-8998		BUS.LICENSE CERTIFICATE	
TEL 604-435-1722		BUS.LICENSE 295066		FAX		BUS.LICENSE CERTIFICATE	

PURSUANT TO THE FIRE BY-LAW, THE FOLLOWING WORK IS HEREBY AUTHORIZED:

TO REMOVE 1 TANK ON SITE. CAPACITY IS 3500 L. SETBACK IS 6'N. BOTTOM OF TANK AT 63". TYPE OF LIQUID IS PETROLEUM.

PERMIT CONDITIONS AND NOTES:

- 001 THE WORK UNDER THIS PERMIT IS AUTHORIZED PURSUANT TO THE FIRE BY-LAW.
- 010 For fuel dispensing site or known contamination site, clearance from Environmental Protection Branch.
- 025 If the work cannot be completed in the same day, the owner must follow the requirements of Section 8.2 of the Vancouver Building By-law for Protection of the Public and Fire Safety on fencing off construction sites.
- 030 For removal: the tanks, together with connected piping and dispensing equipment, shall have all combustible or flammable liquids removed. The tanks and piping must be removed from the ground and purged of vapours. The pipe ends must be permanently sealed by capping or plugging.
- 040 Tank removal must comply with subsection 4.10.3 of the Vancouver Fire By-law.
- 045 Written verification from contractor to District Fire Inspector for work complete.
- 051 Phone the District Fire Inspector at 604-873-7595 for an inspection prior to backfilling. Please arrange for the inspection at least 24 hours in advance.

GENERAL USE	SPECIFICS/LOCATION	AREA (SF)	OCC	GENERAL USE	SPECIFICS/LOCATION	AREA (SF)	OCC
D30	ONE-FAM DWELLING		C				
ITEM	SPECIFICS/REFERENCE	QTY/AMT		ITEM	SPECIFICS/REFERENCE	QTY/AMT	
2010	OIL TANK	1	GU				

DOCUMENTS REQUIRED BEFORE PERMIT IS COMPLETED INCLUDE : FIRE COMPLETION
 APPROVALS REQUIRED BEFORE PERMIT IS COMPLETED INCLUDE : FIRE INSPECTION

AS OWNER OR OWNERS' AGENT, I HAVE VERIFIED THAT THE INFORMATION CONTAINED WITHIN THIS DOCUMENT AND ASSOCIATED PLANS IS CORRECT, AND DESCRIBES A USE, A BUILDING OR A WORK WHICH COMPLIES WITH ALL RELEVANT BY-LAWS AND STATUTES. I ACKNOWLEDGE THAT RESPONSIBILITY FOR BY-LAW COMPLIANCE RESTS WITH THE OWNER AND THE OWNER'S EMPLOYEES, AGENTS AND CONTRACTORS. I WILL INDEMNIFY AND SAVE HARMLESS THE CITY OF VANCOUVER, ITS OFFICIALS, EMPLOYEES AND AGENTS AGAINST ALL CLAIMS, LIABILITIES AND EXPENSES OF EVERY KIND, IN RESPECT OF ANYTHING DONE OR NOT DONE PURSUANT TO THIS APPLICATION OR FACT SHEET OR ENSUING PERMIT, INCLUDING NEGLIGENCE AND/OR THE FAILURE TO OBSERVE ALL BY-LAWS, ACTS OR REGULATIONS.

FEE	AMOUNT	FEE	AMOUNT	SIGNATURE
656 TANK - SFD	300.00			
DATE				
ISSUED BY C BAWN.				
FOR THE				FIRE CHIEF
INVOICE : 447598		TOTAL		\$300.00

2006/07/18 14:14:36

AUDIT COPY