

**From:** "Johnston, Sadhu" <Sadhu.Johnston@vancouver.ca>  
**To:** "Graves, Lynda" <lynda.graves@vancouver.ca>  
**Date:** 5/29/2017 12:08:01 PM  
**Subject:** FW: ENG - Memo to Mayor and Council - Metro Chilco Pump Station - May 26 2017  
**Attachments:** ENG - Memo to Mayor and Council - Metro Chilco Pump Station - May 26 2017.docx  
ATT00001.htm

He sent it on Friday night but didn't copy the correspondence group.

---

**From:** Johnston, Sadhu  
**Sent:** Friday, May 26, 2017 6:33 PM  
**To:** Direct to Mayor and Council - DL  
**Subject:** ENG - Memo to Mayor and Council - Metro Chilco Pump Station - May 26 2017

Good Evening Mayor and Council,

Please see the attached memo from Jerry Dobrovolny providing information on a sewer overflow that is currently taking place:

- The Metro Vancouver owned and operated Chilco pumping station is down due to a BC Hydro outage at Stanley Park.
- This is causing a sewer overflow into the Burrard inlet
- The pumping station is located at the entrance of Stanley Park, and the submerged outfall is immediately north of Brockton Point.
- Metro Vancouver is following their emergency protocols, and has informed EMBC and is performing all necessary environmental monitoring.
- The overflow started at 2:37 PM, and is expected to end at between 6:00 and 7:00 PM this evening.

Best  
Sadhu

**Sadhu Aufochs Johnston** | City Manager  
City of Vancouver | 453 W 12<sup>th</sup> Avenue  
Vancouver | BC V5Y 1V4  
604.873.7627 | [Sadhu.johnston@vancouver.ca](mailto:Sadhu.johnston@vancouver.ca)  
Twitter: sadhuajohnston



## MEMORANDUM

May 26, 2017

TO: Mayor and Council

CC: Sadhu Johnston, City Manager  
Paul Mochrie, Deputy City Manager  
Janice MacKenzie, City Clerk  
Lynda Graves, Manager, Administration Services, City Manager's Office  
Rena Kendall-Craden, Director, Communications  
Kevin Quinlan, Chief of Staff, Mayor's Office  
Katie Robb, Director, Communications, Mayor's Office  
Naveen Girn, Director, Community Relations, Mayor's Office  
Daniel Roberge, Director, Water & Sewer Green Infrastructure

FROM: Jerry Dobrovlny, General Manager of Engineering Services

SUBJECT: Metro Chilco Pump Station Sewer Overflow

---

Metro Vancouver notified the City at 3:43pm this afternoon that their Chilco Pump Station located at the entrance of Stanley Park was down due to a power outage from BC Hydro.

At 2:37pm this afternoon, Metro enacted their emergency response plan as the liquid waste started overflowing into the Burrard inlet through a submerged outfall immediately north of the station off Brockton Point. Metro has informed EMBC and are performing all the necessary environmental monitoring.

The Chilco station is a large station for Metro that roughly services the area north of Nelson, between Stanley Park and Burrard.

Normal operations is expected to resume at 6:00pm today.

Jerry W. Dobrovlny, P. Eng., MBA  
General Manager of Engineering Services

(T) 604.873.7331

(E) [jerry.dobrovlny@vancouver.ca](mailto:jerry.dobrovlny@vancouver.ca)

