

**From:** ["Johnston, Sadhu" <Sadhu.Johnston@vancouver.ca>](mailto:Sadhu.Johnston@vancouver.ca)  
**To:** ["Direct to Mayor and Council - DL"](#)  
**CC:** ["City Manager's Correspondence Group - DL"](#)  
**Date:** 5/28/2018 1:40:41 PM  
**Subject:** Diesel Overflow at Mt Pleasant Community Centre

Greetings Mayor and Council,

We received word a short time ago about a diesel overflow in the underground parkade of the Mount Pleasant Community Centre just after 10am. The information is still coming in but as we understand a city employee was filling the generator in the mechanical room when there was an overflow of between 50 - 100 litres of diesel fuel.

Our staff turned off the ventilation system as a precautionary measure after the overflow to ensure no fumes entered the building.

Vancouver Fire and Rescue are on scene with the HazMat team for clean-up. Traffic in the area was impacted but there was no direct effect on community centre operations.

The overflow has now been fully cleaned up and the parkade is open to staff.

Best,  
Sadhu

**Sadhu Aufochs Johnston** | City Manager  
City of Vancouver | 453 W 12<sup>th</sup> Avenue  
Vancouver | BC V5Y 1V4  
604.873.7627 | [Sadhu.johnston@vancouver.ca](mailto:Sadhu.johnston@vancouver.ca)  
Twitter: sadhuajohnston



**CONFIDENTIALITY NOTICE:** This message and any accompanying documents contain confidential information intended for a specific individual and purpose. This message is private and protected by law. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution, or the taking of any action based on the contents of this information, is strictly prohibited.