

File No.: 04-1000-20-2019-051

March 8, 2019

s.22(1)

Dear s.22(1)

Re: **Request for Access to Records under the Freedom of Information and Protection of Privacy Act (the "Act")**

I am responding to your request of January 28, 2019 for:

VFRS records related to 695 Smithe Street (the business is operating under the name "Gorg-O-Mish"), from January 1, 2011 to January 28, 2019:

- **Correspondence and investigation records;**
- **A list of dates and incident types.**


All responsive records are attached. Some information in the records has been severed, (blacked out), under s.22(1) of the Act. You can read or download this section here: http://www.bclaws.ca/EPLibraries/bclaws_new/document/ID/freeside/96165_00

Under section 52 of the Act, and within 30 business days of receipt of this letter, you may ask the Information & Privacy Commissioner to review any matter related to the City's response to your FOI request by writing to: Office of the Information & Privacy Commissioner, info@oipc.bc.ca or by phoning 250-387-5629.

If you request a review, please provide the Commissioner's office with: 1) the request number (#04-1000-20-2019-051); 2) a copy of this letter; 3) a copy of your original request; and 4) detailed reasons why you are seeking the review.

Yours truly,

Cobi Falconer, FOI Case Manager, for

A handwritten signature in dark ink, appearing to read 'Cobi Falconer', with a long horizontal flourish extending to the right.

Barbara J. Van Fraassen, BA
Director, Access to Information & Privacy

Barbara.vanfraassen@vancouver.ca
453 W. 12th Avenue Vancouver BC V5Y 1V4

*If you have any questions, please email us at foi@vancouver.ca and we will respond to you as soon as possible. Or you can call the FOI Case Manager at 604.871.6584.

Encl.

:ma



Vancouver Fire and Rescue Services

Property - Inspection History Report

Property Address: **695 SMITHE ST**
Building Name: **Gorg-O-Mish Nightclub**

FH District: **08**
FPO District: **24**

Constr. Type: _____
Business Name: _____
Property class: **[None selected]**

Date of Report: **February 14, 2019**
Last Inspection Date: **January 17, 2019**

Inspection Class	Inspected Date	Status	Assigned To	Inspector
FPO General	January 17, 2019	Unsatisfactory	FP General	Motkaluk, Randall

Violation Notice: Issued Received by: previously signed Position: [None selected]

1 - Egress **Status** Satisfactory

Housekeeping of exit must be maintained. Removal of junk in stairwell.

2 - Emergency Lighting **Status** Unsatisfactory

The emergency lighting unit has past its service date and is now in need of servicing by a qualified service contractor.

3 - Fire Alarm Systems **Status** Unsatisfactory

The fire alarm system is missing its service tag. A current tag shall be affixed to the annunciator/control unit by the service contractor.

4 - Fire Extinguishers (Portable) **Status** Satisfactory

The fire extinguisher is missing and shall be replaced.

Note: Reinspection - Unsatisfactory

Met with property representative to inspect premise.
Unable to locate fire alarm system.
Fire extinguishers nsd: 10/18/19
Emergency lighting nsd: 7/20/18 and a fail on one.
Egress clear of debris
Will reinspect in 30 days

Inspection Class	Inspected Date	Status	Assigned To	Inspector
FPO General	July 11, 2018	Unsatisfactory	FP General	Craven, Lee

Violation Notice: Issued Received by: Jay St Germain Position: Employee

1 - Egress **Status** Unsatisfactory

Housekeeping of exit must be maintained. Removal of junk in stairwell.

2 - Fire Alarm Systems **Status** Unsatisfactory

The fire alarm system is missing its service tag. A current tag shall be affixed to the annunciator/control unit by the service contractor.

3 - Fire Extinguishers (Portable) **Status** Unsatisfactory

The fire extinguisher is missing and shall be replaced.

Note: NOV

NOV was issued for the following



Vancouver Fire and Rescue Services

Property - Inspection History Report

Property Address: 695 SMITHE ST
Building Name: Gorg-O-Mish Nightclub

FH District: 08
FPO District: 24

- Exit stairwell has a extreme amount of clutter and must be cleared.
- Fire alarm tags missing
- Could not locate fire extinguishers.

No sprinklers in night club. On my list for night inspection

Inspection Class	Inspected Date	Status	Assigned To	Inspector
Night Inspection	December 31, 2015	Satisfactory	FP General	Short, John

1 Means of Egress. - 1420 Remove obstructions from means of egress	Status Satisfactory
---	----------------------------

Article 2.7.1.6.
Maintenance

Sentence:

- 1) Means of egress shall be maintained in good repair and free of obstructions. [See Appendix A]

Appendix:

A-2.7.1.6(1) Means of Egress.

Where a fire escape is ordered to be replaced or rebuilt, a Professional Engineer's certification is generally required to ascertain that the fire escape is structurally sound. The authority comes from Sentence 1.4.4.1.(1) of this By-law.

2. Exit Lighting / Emergency Lighting. - 2850 Inspect test and tag all emergency lights	Status Satisfactory
--	----------------------------

Article 6.7.1.7.
Inspection of Emergency Lights

Sentence:

- 1) Except as provided in Article 6.7.1.6., emergency lights shall be inspected and tagged at intervals not greater than 12 months to ensure that they are functional.

Note: Recheck

Recheck from previous Night Inspection.

Inspected with Padra Farhanga, club owner.

Also talked to Abdul Saboor Khudayar, Building owners son.

Door hold open device off of door.

Rear exit clear with the exception of some small plywood sheets that were asked to be moved.

E. Lighting unit that was tested and tagged but failed to work is now working.

Have to keep rear exit stairs clear.

Inspection Class	Inspected Date	Status	Assigned To	Inspector
Night Inspection	November 29, 2015	Unsatisfactory	FP General	Short, John

Violation Notice: Issued

Received by: Dariu Dan Ruisshiee

Position: Business Owner

1 Means of Egress. - 1420 Remove obstructions from means of egress	Status Unsatisfactory
---	------------------------------

Article 2.7.1.6.
Maintenance

Sentence:

- 1) Means of egress shall be maintained in good repair and free of obstructions. [See Appendix A]

Appendix:



Vancouver Fire and Rescue Services

Property - Inspection History Report

Property Address: 695 SMITHE ST
Building Name: Gorg-O-Mish Nightclub

FH District: 08
FPO District: 24

A-2.7.1.6(1) Means of Egress.

Where a fire escape is ordered to be replaced or rebuilt, a Professional Engineer's certification is generally required to ascertain that the fire escape is structurally sound. The authority comes from Sentence 1.4.4.1.(1) of this By-law.

2 Exit Lighting / Emergency Lighting. - 2850 Inspect test and tag all emergency lights Status Unsatisfactory

Article 6.7.1.7.
Inspection of Emergency Lights

Sentence:

- 1) Except as provided in Article 6.7.1.6., emergency lights shall be inspected and tagged at intervals not greater than 12 months to ensure that they are functional.

Note: Night Inspection with Business Owner

Night Inspection with Business Owner.

- 1- Repair Emergency Lighting- (rear staircase, front entrance)
 - 2- Remove Items from staircases- (dirt/ soil, ping pong table, cardboard. speakers)
 - 3- Remove Unauthorized hold open devices (elephants feet on doors)
- Condition of rear staircase water damage emailed to COV Building.

Inspection Class	Inspected Date	Status	Assigned To	Inspector
Night Inspection	June 15, 2011	Satisfactory	FP General	Burns, Jeffrey

Inspection Class	Inspected Date	Status	Assigned To	Inspector
Night Inspection	February 27, 2010	Satisfactory	FP General	Short, John

Note: Gate off rear exit

Gate has been taken off rear exit.
Also debris cleared from rear exit.

Inspection Class	Inspected Date	Status	Assigned To	Inspector
Night Inspection	February 27, 2010	Satisfactory	FP General	Clinaz, Mauro

Note: Gate off of rear exit

Gate off rear emergency exit and debris cleared away.

Inspection Class	Inspected Date	Status	Assigned To	Inspector
Night Inspection	February 20, 2010	Satisfactory	FP General	Clinaz, Mauro

Note: olympic enforment

night club not open for business till midnight. exit securtiy gate to be removed.

Inspection Class	Inspected Date	Status	Assigned To	Inspector
FPO General	July 23, 2008	Satisfactory	FP General	Tierney, David



Vancouver Fire and Rescue Services

Property - Inspection History Report

Property Address: 695 SMITHE ST
Building Name: Gorg-O-Mish Nightclub

FH District: 08
FPO District: 24

1 Fire Extinguishers. - 2650 Inspect Test and Tag all extinguishers	Status Unsatisfactory
--	------------------------------

Article 6.2.4.1.

Inspection, Testing and Maintenance

Sentence:

- 1) Except as otherwise required in this Section, inspection, testing, maintenance and recharging of portable extinguishers shall be in conformance with NFAP 10, "Portable Fire Extinguishers."

2 Exit Lighting / Emergency Lighting. - 2850 Inspect test and tag all emergency lights	Status Unsatisfactory
---	------------------------------

Article 6.7.1.7.

Inspection of Emergency Lights

Sentence:

- 1) Except as provided in Article 6.7.1.6., emergency lights shall be inspected and tagged at intervals not greater than 12 months to ensure that they are functional.

Inspection Class FPO General	Inspected Date July 23, 2008	Status Satisfactory	Assigned To FP General	Inspector Tierney, David
--	--	-------------------------------	----------------------------------	------------------------------------

Inspection Class Fire Safety Plan Review	Inspected Date February 26, 2003	Status Satisfactory	Assigned To FP General	Inspector Nygard, Gary
--	--	-------------------------------	----------------------------------	----------------------------------

EC Incident Type	Case Number	Street Name	Street Number	Date
s.22(1)	110010222	SMITHE	695	3/28/2011
	110031428	SMITHE	695	9/11/2011
	110043951	SMITHE	695	12/17/2011
Response - Cancelled - On Scene	130001697	SMITHE	695	1/14/2013
s.22(1)	130009218	SMITHE	695	3/18/2013
	130013137	SMITHE	695	4/20/2013
	130032194	SMITHE	695	9/1/2013
	130033179	SMITHE	695	9/8/2013
	130035187	SMITHE	695	9/22/2013
Response - Cancelled - On Scene	130035190	SMITHE	695	9/22/2013
Response - Cancelled - On Scene	130042485	SMITHE	695	11/16/2013
s.22(1)	140000568	SMITHE	695	1/5/2014
	140006003	SMITHE	695	2/16/2014
	140007793	SMITHE	695	3/2/2014
Public Service - Assisted BCAS/Police	140009585	SMITHE	695	3/16/2014
s.22(1)	140016019	SMITHE	695	5/3/2014
	140018916	SMITHE	695	5/25/2014
Response - Cancelled - On Scene	140029206	SMITHE	695	8/3/2014
Response - Cancelled - On Scene	140032143	SMITHE	695	8/23/2014
s.22(1)	140033359	SMITHE	695	8/31/2014
Response - Cancelled - On Scene	140037436	SMITHE	695	9/28/2014
Public Service - Trapped In Elevator	140050636	SMITHE	695	12/31/2014
s.22(1)	150025458	SMITHE	695	6/25/2015
Response - Cancelled - On Scene	160004625	SMITHE	695	1/31/2016
Response - Cancelled - On Scene	160013070	SMITHE	695	3/27/2016
s.22(1)	160028881	SMITHE	695	7/3/2016
	160035827	SMITHE	695	8/13/2016
	160051488	SMITHE	695	11/12/2016
Response - Cancelled - On Scene	170002830	SMITHE	695	1/15/2017
Response - Cancelled - On Scene	170005484	SMITHE	695	1/29/2017
Public Service - Locked In/Out	170007799	SMITHE	695	2/11/2017
s.22(1)	170019860	SMITHE	695	4/15/2017
	170025260	SMITHE	695	5/15/2017
	170058000	SMITHE	695	11/4/2017
Response - Cancelled - En Route	170061977	SMITHE	695	11/27/2017
s.22(1)	180009505	SMITHE	695	2/24/2018
	180023257	SMITHE	695	5/12/2018
	180029882	SMITHE	695	6/23/2018
	180035687	SMITHE	695	8/4/2018
Response - Cancelled - On Scene	180035699	SMITHE	695	8/4/2018
s.22(1)	180039764	SMITHE	695	9/2/2018