

File No.: 04-1000-20-2019-495

August 29, 2019

s.22(1)

Dear s.22(1)

Re: **Request for Access to Records under the Freedom of Information and Protection of Privacy Act (the "Act")**

I am responding to your request of July 31, 2019 for:

Any documents related to an oil tank removal project at 6526 Wiltshire Street, from January 1, 2000 to July 30, 2019.

All responsive records are attached. Some information in the records has been severed, (blacked out), under s.22(1) of the Act. You can read or download this section here: http://www.bclaws.ca/EPLibraries/bclaws_new/document/ID/freeside/96165_00

Under section 52 of the Act, and within 30 business days of receipt of this letter, you may ask the Information & Privacy Commissioner to review any matter related to the City's response to your FOI request by writing to: Office of the Information & Privacy Commissioner, info@oipc.bc.ca or by phoning 250-387-5629.

If you request a review, please provide the Commissioner's office with: 1) the request number (#04-1000-20-2019-495); 2) a copy of this letter; 3) a copy of your original request; and 4) detailed reasons why you are seeking the review.

Yours truly,



Barbara J. Van Fraassen, BA
Director, Access to Information & Privacy

Barbara.vanfraassen@vancouver.ca
453 W. 12th Avenue Vancouver BC V5Y 1V4

*If you have any questions, please email us at foi@vancouver.ca and we will respond to you as soon as possible. Or you can call the FOI Case Manager at 604.871.6584.

Encl.

:pm

CITY OF VANCOUVER

DATE ISSUED MARCH 08, 2012		PERMIT TYPE FIRE PREVENTION DIVISION PERMIT				PERMIT NUMBER P FI 409625	
LEGAL DESCRIPTION LT 6 BLK AA PL VAP4185 DL 526 OF PLAN VAP4185 (cont'd)					ADDRESS 6526 WILTSHIRE ST		
ADDITIONAL ADDRESS INFORMATION					SPECIFICS		
APPLICATION DATE MAR 08, 2012	PURPOSE REMOVAL	PROJECT VALUE	ASSESSED VALUE	PLANS	METRIC NO	PLACE NAME	
TEMPORARY PERMIT DATES		TEMPORARY USE DATES				SUBTYPE	
APPLICANT CONTRACTOR ECONO TANK SERVICES 9715 120A ST SURREY BC V3V 4H7					CONTACT 2		
CONTACT 3					CO-ORDINATE 121-790-32-0000		
TEL 778-862-1493	BUS LICENSE 423981	TEL	BUS LICENSE	TEL	BUS LICENSE		
FAX	CERTIFICATE	FAX	CERTIFICATE	FAX	CERTIFICATE		

PURSUANT TO THE FIRE BY-LAW, THE FOLLOWING WORK IS HEREBY AUTHORIZED:

TO REMOVE 1 TANK ON SITE. CAPACITY IS 636 GALS. SETBACK IS 8'. BOTTOM OF TANK AT 89".

PERMIT CONDITIONS AND NOTES:

- 001 THE WORK UNDER THIS PERMIT IS AUTHORIZED PURSUANT TO THE FIRE BY-LAW.
- 010 For fuel dispensing site or known contamination site, clearance from Environmental Protection Branch.
- 020 Clearance is required from the Engineering Department, Streets Division, for work affecting
- 030 For removal: the tanks, together with connected piping and dispensing equipment, shall have all combustible or flammable liquids removed. The tanks and piping must be removed from the ground and purged of vapours. The pipe ends must be permanently sealed by capping or plugging.
- 040 Tank removal must comply with subsection 4.10.3 of the Vancouver Fire By-law.
- 046 Written verification from applicant after work is completed to:
Attention: Customer Service Lieutenant, 201-456 W Broadway, Vancouver, B.C., V5Y 1R3
- 051 Phone the District Fire Inspector at 604-873-7595 for an inspection prior to backfilling. Please arrange for the inspection at least 24 hours in advance.

GENERAL USE	SPECIFICS/LOCATION	AREA (SF)	OCC	GENERAL USE	SPECIFICS/LOCATION	AREA (SF)	OCC
D DWELLING USES							
ITEM	SPECIFICS/REFERENCE	QTY/AMT		ITEM	SPECIFICS/REFERENCE	QTY/AMT	
2010 OIL TANK		1 CU					
DOCUMENTS REQD BEFORE PERMIT IS COMPLETED INCLUDE	:	FIRE COMPLETION					
APPROVALS REQD BEFORE PERMIT IS COMPLETED INCLUDE	:	FIRE INSPECTION					

AS OWNER OR OWNERS' AGENT, I HAVE VERIFIED THAT THE INFORMATION CONTAINED WITHIN THIS DOCUMENT AND ASSOCIATED PLANS IS CORRECT, AND DESCRIBES A USE, A BUILDING OR A WORK WHICH COMPLIES WITH ALL RELEVANT BY-LAWS AND STATUTES. I ACKNOWLEDGE THAT RESPONSIBILITY FOR BY-LAW COMPLIANCE RESTS WITH THE OWNER AND THE OWNER'S EMPLOYEES, AGENTS AND CONTRACTORS. I WILL INDEMNIFY AND SAVE HARMLESS THE CITY OF VANCOUVER, ITS OFFICIALS, EMPLOYEES AND AGENTS AGAINST ALL CLAIMS, LIABILITIES AND EXPENSES OF EVERY KIND, IN RESPECT OF ANYTHING DONE OR NOT DONE PURSUANT TO THIS APPLICATION OR FACT SHEET OR ENSUING PERMIT, INCLUDING NEGLIGENCE AND/OR THE FAILURE TO OBSERVE ALL BY-LAWS, ACTS OR REGULATIONS.

FEE	AMOUNT	FEE	AMOUNT	SIGNED BY	ECONO TANK SERVICES
656 TANK - SFD	300.00			DATE	SEE APPLICATION
				ISSUED BY	C BAWN
				FOR THE	FIRE CHIEF
INVOICE: 660373		TOTAL		\$300.00	

PSD2000.01 REVISED FEB/08

24 HR

City of Vancouver

Fire & Rescue Services



City of Vancouver
Fire & Rescue Services - Fire Prevention Division
TANK REMOVAL OR ABANDONMENT PERMIT APPLICATION

FI 409625

Please fill out boxed area only:

Property Address <u>6526 Wiltshire</u>	
Permit Applicant Is: (please print) Name <u>Econolent Services</u> Address <u>9715 120 A ST</u> City <u>Surrey</u> Postal Code <u>V3V 4H7</u> Phone # <u>778 862 1493</u> Contractor <input checked="" type="checkbox"/> Business license no. <u>928921</u> Owner <input type="checkbox"/> Other <input type="checkbox"/> Specify _____	Property Owner Is: (please print) Name <u>s.22(1)</u> Address <u>6526 WILTSHIRE</u> City <u>Vancouver</u> Postal Code _____ Phone # _____
Use of Property <input type="checkbox"/> Site Plan Eng. Letter - Yes / No	Building Permit Associated: BU _____ Type of Liquid (gasoline petroleum)

Requested Activity or Service			
<input checked="" type="checkbox"/> Remove	1 tank(s) on site. Capacity (gal/L) <u>636 gal</u>	Setback <u>8'</u>	bottom of tank at <u>89"</u>
<input type="checkbox"/> Abandonment	_____ tank(s) on site. Capacity (gal/L) _____	Setback _____	bottom of tank at _____
Subject to the Following Conditions and Notes: — for fuel dispensing site or known contamination site, clearance from Environmental Protection Branch — separate building permit for excavation and shoring, plus modified geotechnical engineer's letter — clearance from Engineering Department - Streets Division for work affecting City property X if work cannot be completed in the same day, owner must follow requirements in VBBL Section 8.2 for Protection of the Public and Fire Safety on fencing off construction site. X for removal: the tanks, together with connected piping and dispensing equipment, shall have all combustible or flammable liquids removed. The tanks and piping must be removed from the ground and purge of vapours. The pipe ends must be permanently sealed by capping or plugging. for abandonment: pump out remaining content, steam clean interior, and fill with sand-concrete slurry X tank removal must comply with subsection 4.10.3 of the Vancouver Fire Bylaw X written verification from applicant after work is completed to: Attn: Fire Prevention Division, Suite #201- 456 W. Broadway, Vancouver, B.C. V5Y 1R3. X phone the Office Captain at (604) 873 7593 for an inspection prior to backfilling. Please arrange for the inspection at least 24 hours in advance. other: _____			

Application is <u>LT JIM KENNEDY</u> ACCEPTED BY <u>[Signature]</u> WITNESSED BY <u>[Signature]</u> Signature of Applicant <u>[Signature]</u> Date of Application <u>8 March</u>	<p>THIS IS NOT A PERMIT</p> Permit Fee \$300 Account Code 190200 23300 9200 Date Entered _____
--	---

Please take this signed application form to the 2nd floor Trades Clerk Counter for the fire permit issuance

Permit	FI409625	Street number		To		Street name		<input type="button" value="Search"/>
--------	----------	---------------	--	----	--	-------------	--	---------------------------------------

General Information









Permit	FI409625	Type	FI - FIRE
Permit address	6526 WILTSHIRE ST	Status	ISSUED
Specific address		Opened	08 Mar 2012
Place name		Issued	08 Mar 2012
Addressing data			
Coordinate	121 - 790 - 32 - 0000		
Legal Description	LT 6 BLK AA PL VAP4185 DL 526 OF PLAN VAP4185 (cont'd)		
Project value	\$0.00	Purpose to	610 - REMOVAL
Assessed value	\$0.00	Subtype	-
Temporary bldg		to	
Temporary use		to	
Complexity	-	Sets of plans	0
Signature on	APP - APPLICATION	Metric?	

Permit	<input type="text" value="FI409625"/>	Street number	<input type="text"/>	To	<input type="text"/>	Street name	<input type="text"/>	<input type="button" value="Search"/>
--------	---------------------------------------	---------------	----------------------	----	----------------------	-------------	----------------------	---------------------------------------

Project Description

TO REMOVE 1 TANK ON SITE. CAPACITY IS 636 GALS. SETBACK IS 8'. BOTTOM OF TANK AT 89".

Permit	FI409625	Street number		To		Street name		Search
--------	----------	---------------	--	----	--	-------------	--	--------

Note Types						
Note Type			Number of notes for this permit			
	03 - SUBJECT TO CONDITION		7			
Notes						
	Number	Title	Included?	List seq	Updated By	Date Updated
	001	STANDARD CONDITIONS	YES	001	C BAWN	08 Mar 2012
THE WORK UNDER THIS PERMIT IS AUTHORIZED PURSUANT TO THE FIRE BY-LAW.						
	010	CLEARANCE FROM EVN PROT BRANCH	YES	010	C BAWN	08 Mar 2012
For fuel dispensing site or known contamination site, clearance from Environmental Protection Branch.						
	020	CLEARANCE FROM ENG DEPARTMENT	YES	020	C BAWN	08 Mar 2012
Clearance is required from the Engineering Department, Streets Division, for work affecting						
	030	TANKS WITH CONNECTED PIPING	YES	030	C BAWN	08 Mar 2012
For removal: the tanks, together with connected piping and dispensing equipment, shall have all combustible or flammable liquids removed. The tanks and piping must be removed from the ground and purged of vapours. The pipe ends must be permanently sealed by capping or plugging.						
	040	TANK REMOVAL - SECTION 4.10	YES	040	C BAWN	08 Mar 2012
Tank removal must comply with subsection 4.10.3 of the Vancouver Fire By-law.						
	046	WRITTEN VERIFICATION	YES	046	C BAWN	08 Mar 2012
Written verification from applicant after work is completed to:						
Attention: Customer Service Lieutenant, 306-456 W Broadway, Vancouver, B.C., V5Y 1R3						
	051	CONTACT DISTRICT FIRE INSPEC	YES	051	C BAWN	08 Mar 2012
Phone the District Fire Inspector at 604-873-7595 for an inspection prior to backfilling. Please arrange for the inspection at least 24 hours in advance.						