

File No.: 04-1000-20-2020-304

June 19, 2020

s.22(1)

Dear s.22(1)

Re: **Request for Access to Records under the Freedom of Information and Protection of Privacy Act (the "Act")**

I am responding to your request of June 2, 2020 for:

**Report from the Sewer Operations Branch examination of the sewage and flooding source at the ground floor retail location of Canoe Westcan Operation Corp., at 700 West Broadway on May 29, 2020 (Sewer Operations Branch File #14040461).**

All responsive records\* are attached. Some information in the records has been severed, (blacked out), under s.22(1) of the Act. You can read or download this section here: [http://www.bclaws.ca/EPLibraries/bclaws\\_new/document/ID/freeside/96165\\_00](http://www.bclaws.ca/EPLibraries/bclaws_new/document/ID/freeside/96165_00).

\*Please note, this work was completed on May 28, 2020 not May 29, 2020 as requested.

Under section 52 of the Act you may ask the Information & Privacy Commissioner to review any matter related to the City's response to your request. The Act allows you 30 business days from the date you receive this notice to request a review by writing to: Office of the Information & Privacy Commissioner, [info@oipbc.bc.ca](mailto:info@oipbc.bc.ca) or by phoning 250-387-5629.

If you request a review, please provide the Commissioner's office with: 1) the request number assigned to your request (#04-1000-20-2020-304); 2) a copy of this letter; 3) a copy of your original request for information sent to the City of Vancouver; and 4) detailed reasons or grounds on which you are seeking the review.

Please do not hesitate to contact the Freedom of Information Office at [foi@vancouver.ca](mailto:foi@vancouver.ca) if you have any questions.

Yours truly,

[Signature on file]

**Barbara J. Van Fraassen, BA**  
**Director, Access to Information & Privacy**

[Barbara.vanfraassen@vancouver.ca](mailto:Barbara.vanfraassen@vancouver.ca)

*453 W. 12th Avenue Vancouver BC V5Y 1V4*

\*If you have any questions, please email us at [foi@vancouver.ca](mailto:foi@vancouver.ca) and we will respond to you as soon as possible. Or you can call the FOI Case Manager at 604.871.6584.

Encl.

:kt

# Work Slip

SAP Charge #		Address & Location: 700 W BROADWAY			Responsible	
EES1204869						
Work Order #		Work Order Activity			Created Date	
		S/L/B				
Group Project #		Problem	Sub Activity	Assigned To		Crew ID
Work Order Comments: 1/s c/o EAST WALL AT P/L.						
Reference #1					Billable?	
Reference #2						
Collection Agency			Collection Method		Zone	Beat
Service Request #						
Contact Name			Contact Phone		Contact Type	
Asset Type		Asset ID #	B.U.N	Status	Asset Area	Map # (Facet) District
Asset Details:						
Safety & Asset Notes:						
PM Sched.	Maint. Sched.	Due Date	Zone	Last Completed Work Order		
Crew Comments						
<p>CREW ARRIVED, MILANI PLUMBING WAS THERE LOOKING FOR C/O. SEWAGE POORING OUT OF TOILET, ALL OVER. CREW FOUND C/O ON EAST WALL AT P/L. OPENED CAP, SEWAGE POORED OUT, CREW USED R/R + CUTTER. CLEARED AT BOTTOM OF C/O WHERE CONNECTION WYED IN. CCTV'ED, FOUND ROOT JUST BEYOND WYE. THE CITY SIDE WAS CLEAR TO MAIN.</p> <p style="text-align: right;">JOB COMPLETE</p>						
Work Completed Date: MAY 28/2020		Print Name: s.22(1) / s.22(1)		Crew ID: 35		

CONTACT: \_\_\_\_\_ PHONE: \_\_\_\_\_ INVOICE #: **51190**

BILLING ADDRESS: \_\_\_\_\_ DATE: **MAY 28/2020** SIGNATURE: \_\_\_\_\_ WITH  WITHOUT

TIME STARTED: **11:50 AM** TIME END: \_\_\_\_\_ Day After Call

WORKED FROM: \_\_\_\_\_  
 ADDITIONAL ACCESS LOCATION DETAILS  
 INSIDE  Additional details: \_\_\_\_\_  
 OUTSIDE  \_\_\_\_\_  
 TOILET  \_\_\_\_\_  
 STACK  \_\_\_\_\_  
 C/O  \_\_\_\_\_  
 SUMP  Distance from access location to main: **16.0** m  
 D/U  \_\_\_\_\_

PRECONDITION WITH CCTV  
 GOOD   
 FAIR   
 POOR

REQUIRE TO CLEAN  
 YES   
 NO

ACTIVITY  
 SLM   
 SLB   
 PLUGGED MAIN   
 SPECIALS   
 CB   
 CCTV   
 TV FOR REUSE   
 INVESTIGATION   
 INSTALL C/O







EQUIPMENT USED  
 HAND RODS   
 ROTO-ROOTER   
 LARGE CUTTER   
 SMALL CUTTER   
 HUMMINGBIRD   
 BRUSH   
 FLUSHER   
 CCTV   
 OTHER: \_\_\_\_\_


DEFECT/BLOCKAGE LOCATION OF DEFECT / BLOCKAGE  
 ROOTS  FROM ACCESS POINT  
 LIGHT  INSIDE PL  \_\_\_\_\_ M to \_\_\_\_\_ M  
 MEDIUM  AT PL  **16.0** M  
 HEAVY  OUTSIDE PL  \_\_\_\_\_ M to \_\_\_\_\_ M  
 GREASE  NO BLOCKAGE   
 SOLIDS  ADDITIONAL INFO: \_\_\_\_\_  
 DEBRIS  \_\_\_\_\_  
 STRUCTURAL  \_\_\_\_\_  
 OTHER/ UNKNOWN: \_\_\_\_\_

ASSET TYPE  
 SAN CONN   
 SAN MAIN   
 COMB CONN   
 COMB MAIN   
 STORM CONN   
 STORM MAIN   
 METRO MAIN   
 COMPLETE  INCOMPLETE

AFTER CLEANING  
 GOOD   
 POOR   
 FAIR   
 SOUND TEST  
 GOOD   
 POOR   
 FAIR

MAIN CLEANING REQ.  
 BLOCKED: YES  NO   
 FLUSH   
 ROOT CUT   
 MH #: \_\_\_\_\_ TO  
 MH #: \_\_\_\_\_  
 ADDITIONAL WORK

- SYMBOLS  
 TREE   
 SHRUB   
 HEDGE   
 SEWER   
 MANHOLE   
 STOPPAGE 



CONNECTION DEPTH @ PL \_\_\_\_\_ M PL IS  $\phi$  \_\_\_\_\_ M FROM C/O DEPTH @ MAIN \_\_\_\_\_ M  
 PRIVATE SIDE REPLACED   
 CITY SIDE REPLACED  PL OFFSET \_\_\_\_\_ M **N S E W** of **N S E W** DEPTH @ HOUSE \_\_\_\_\_ M

WYE MEASUREMENTS: \_\_\_\_\_ M FROM DOWNSTREAM MH \_\_\_\_\_ M B/M  
 FOR OFFICE USE ONLY  
 MAINTAIN SCHED  ADD TO SLM PROGRAM  NO CHARGE  DATE ADDED TO PROGRAM: \_\_\_\_\_  
 CIPP CANDIDATE  FULL SURVEY REQ  INVITE TO SLM W/SIG  SHARE   
 CCTV  CHANGE FREQUENCY: REMOVE FROM PROG  CHARGE  INVOICE CANCELLED BY: \_\_\_\_\_  
 SEND LETTER # \_\_\_\_\_ 6 MTH  12 MTH  CHANGE WITHOUT to WITH SIGNATURE   
 18 MTH  24 MTH  CHANGE WITH to WITHOUT SIGNATURE  DATE INVOICE CANCELLED: \_\_\_\_\_

COMMENTS: \_\_\_\_\_ INITIALS: \_\_\_\_\_ DATE: \_\_\_\_\_

SUPT COMMENTS: \_\_\_\_\_  
 City of Vancouver - FOI 2020-304 Page 2 of 2