

File No.: 04-1000-20-2021-573

December 13, 2021

s.22(1)

Dear s.22(1)

Re: **Request for Access to Records under the Freedom of Information and Protection of Privacy Act (the "Act")**

I am responding to your request of November 8, 2021 under the ***Freedom of Information and Protection of Privacy Act, (the Act)***, for:

**Report for Reference No. 14984751 regarding a blocked drain at Protrans BC's Marine Drive Station on April 28, 2021.**

All responsive records are attached.

Under section 52 of the Act, and within 30 business days of receipt of this letter, you may ask the Information & Privacy Commissioner to review any matter related to the City's response to your FOI request by writing to: Office of the Information & Privacy Commissioner, [info@oipc.bc.ca](mailto:info@oipc.bc.ca) or by phoning 250-387-5629.

If you request a review, please provide the Commissioner's office with: 1) the request number (#04-1000-20-2021-573); 2) a copy of this letter; 3) a copy of your original request; and 4) detailed reasons why you are seeking the review.

Yours truly,

[Signature on file]

**Barbara J. Van Fraassen, BA**  
**Director, Access to Information & Privacy**

[Barbara.vanfraassen@vancouver.ca](mailto:Barbara.vanfraassen@vancouver.ca)  
453 W. 12th Avenue Vancouver BC V5Y 1V4

If you have any questions, please email us at [foi@vancouver.ca](mailto:foi@vancouver.ca) and we will respond to you as soon as possible. Or you can call the FOI Case Manager at 604.871.6584.

Encl.

:ag

# TEOD Work Slip

SAP Network #	Address	Lane	
EES1295593	8400 - 8699 CAMBIE ST		
Work Order #	WO Short Description		Reason
1295593	8430 Cambie		OTHER
Activity Type	Sub Activity Type	Problem	Priority
Maintenance	SINVEST		[ ] Emergency [ ] High

**SAFETY WARNING:**

Group Project	Ref #1	Responsibility	Parent SAP Network #
		SO	

Service Request #	Incident Date	311 Case #	Contact Name	Contact #
1773549	4/28/2021	101014984751	Westrim Plumbing and Heating Ltd	6043401441

Asset Category	Asset ID	Status	Asset Area	Sub Area	District
Cleanout	1938631		CBE07		

**Temporary Operation**

--	--	--	--	--

WO Created Date	Schedule Start	Last Completed WO Activity	Last Completed WO Desc
Apr 28, 2021		Maintenance	8430 Cambie

**JOB DETAILS**

check MH- -- standing water-

April 28,2021

- 150m main was plugged
- Flusher truck after clearing brought back grease and asphalt
- note drains @ skytrain station seem to be connected to san main

**Asset Comments:**

# TEOD Work Slip

Assigned By	Assigned Date	Assigned Time	Arrival Date	Arrival Time
	2021/04/28	15:01	2021/04/28	07:17

**PROBLEM FOUND**

**WORK COMPLETED**

Functional Test

Stray Voltage Check

**OTHER WORK REQUIRED**

**ADDITIONAL COMMENTS**

Completed Date	Completed Time	Crew Member Name	Crew Member Name	Crew Member Name
Apr 28, 2021	07:17	CALLUM MALONEY		

Print Name	Signature	Truck #

