

ELECTRICAL PLAN EXAMINER'S TRANSMITTAL FORM

(To be completed by a CP / Electrical Engineer and submitted to the Electrical Plan Examiner with Electrical Plans)

Address: _____ Building Permit No.: _____

Major Occupancy Classification: _____ Construction Article: _____

New Construction: Addition: Alteration:

Please check the appropriate boxes accordingly.

Attachment to Bulletin 2001-008-BU/EL

Revised March 6, 2020

<input type="checkbox"/>	<input type="checkbox"/>	Schedule B provided – VBBL Division C 2.2.7.
<input type="checkbox"/>	<input type="checkbox"/>	Building is required to be of non-combustible construction – VBBL Subsection 3.2.2.
<input type="checkbox"/>	<input type="checkbox"/>	High building – VBBL Subsection 3.2.6.
<input type="checkbox"/>	<input type="checkbox"/>	Building on designated flood plain - Needs to protect electrical equipment – VBBL Division C 2.2.9.
<input type="checkbox"/>	<input type="checkbox"/>	Electrical equipment and wiring in plenum spaces – VBBL Article 3.6.4.3.
<input type="checkbox"/>	<input type="checkbox"/>	Smoke alarms are required – VBBL Article 3.2.4.20.
<input type="checkbox"/>	<input type="checkbox"/>	Permanently connected carbon monoxide (CO) alarms are required – VBBL Article 6.9.3.1.
<input type="checkbox"/>	<input type="checkbox"/>	Fire alarm system is required – VBBL Subsection 3.2.4.
<input type="checkbox"/>	<input type="checkbox"/>	2-stage fire alarm system is provided – VBBL Sentence 3.2.4.3.(1).
<input type="checkbox"/>	<input type="checkbox"/>	Voice communication is required – VBBL Articles 3.2.4.22., 3.2.6.8.
<input type="checkbox"/>	<input type="checkbox"/>	Radio antenna system is required – VBBL Article 3.2.5.20. (See Note A-3.2.5.20.)
<input type="checkbox"/>	<input type="checkbox"/>	Strobe lights (visible signal devices) are provided – VBBL Article 3.2.4.19.
<input type="checkbox"/>	<input type="checkbox"/>	Audible signal devices are provided for persons on roof deck or balcony – VBBL Sentence 3.2.4.18.(13).
<input type="checkbox"/>	<input type="checkbox"/>	Indicator lamps for separate zone indications are provided for annunciator – VBBL Article 3.2.4.8.(11).
<input type="checkbox"/>	<input type="checkbox"/>	Signal to fire department is required – VBBL Article 3.2.4.7.
<input type="checkbox"/>	<input type="checkbox"/>	Electrical supervision is provided for fire alarm system. A trouble signal indicating the nature of the trouble in accordance with Sentence (3) and (5) will be transmitted to a Fire Signal Receiving Centre – VBBL Article 3.2.4.9.
<input type="checkbox"/>	<input type="checkbox"/>	Electromagnetic door locks – VBBL Article 3.4.6.16.
<input type="checkbox"/>	<input type="checkbox"/>	Door Holders (Hold-Open Devices) and Door Closers - VBBL Article 3.1.8.14., CAN/ULC-S524.
<input type="checkbox"/>	<input type="checkbox"/>	Manual switches for smoke control & smoke venting equipment at the CACF - VBBL Articles 3.2.6.2.; 3.2.6.7.
<input type="checkbox"/>	<input type="checkbox"/>	Emergency Lighting is required – VBBL Article 3.2.7.3.
<input type="checkbox"/>	<input type="checkbox"/>	Exit signs are required – VBBL Article 3.4.5.1.
<input type="checkbox"/>	<input type="checkbox"/>	Protection of emergency conductors is required – VBBL Article 3.2.7.10.
<input type="checkbox"/>	<input type="checkbox"/>	Emergency generator is required – VBBL Article 3.2.7.9.
<input type="checkbox"/>	<input type="checkbox"/>	By-pass isolation in a transfer switch is required – CSA C282
<input type="checkbox"/>	<input type="checkbox"/>	Sprinklers are required – VBBL Article 3.2.5.12.
<input type="checkbox"/>	<input type="checkbox"/>	Listed heat tracing system for sprinkler system is required – Bulletin 2020-003-BU/EL/SP
<input type="checkbox"/>	<input type="checkbox"/>	Standpipe system is required – trouble signal is provided on annunciator – VBBL Sentence 3.2.4.9.(2).
<input type="checkbox"/>	<input type="checkbox"/>	VBBL Alternative Solution related to the life safety system
<input type="checkbox"/>	<input type="checkbox"/>	Electric motor-driven fire pump is required – VBBL Sentence 3.2.5.18.(1).
<input type="checkbox"/>	<input type="checkbox"/>	Residential fire warning system is provided or required – VBBL Sentence 3.2.4.21.(1) / 9.10.19.8.(1)
<input type="checkbox"/>	<input type="checkbox"/>	Dwelling units contain pre-wired outlet boxes for Enhanced Accessibility – VBBL Subclause 3.8.3.1.(2)(f)(ii)
<input type="checkbox"/>	<input type="checkbox"/>	Dwelling units provided with special outlet boxes to allow operation of strobe lights – VBBL Sentence 3.8.2.12.(5)
<input type="checkbox"/>	<input type="checkbox"/>	Controls, switches, outlets, receptacles are provided in conformance with VBBL Articles 3.8.2.6.; 3.8.5.7.
<input type="checkbox"/>	<input type="checkbox"/>	Parking spaces are provided with an energized outlet for Level 2 EV charging – Bulletin 2019-006-BU/EL
<input type="checkbox"/>	<input type="checkbox"/>	EVEMS is implemented; 12 kWh / EVSE performance level is provided – Bulletin 2019-006-BU/EL
<input type="checkbox"/>	<input type="checkbox"/>	Building is electrically designed to meet the energy efficiency requirements – VBBL Section 10.2.
<input type="checkbox"/>	<input type="checkbox"/>	High voltage installation – CE Code Section 36
<input type="checkbox"/>	<input type="checkbox"/>	CE Code Section 64 - Renewable energy systems: Solar photovoltaic systems <input type="checkbox"/> Storage batteries <input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	Owner is advised that an annual permit must be obtained – Electrical By-law No.5563 . Bulletin 2019-003-EL

CP/Electrical Engineer: _____ Date: _____

DOC/2020/048240